



America

CERTIFICATE

No. U8 020822 0001 Rev. 00

Holder of Certificate: **ARI-Armaturen**
Albert Richter GmbH & Co. KG
Mergelheide 56 - 60
33758 Schloß Holte-Stukenbrook
GERMANY

Certification Mark:



Product: **Control Equipment**
(Thrust Actuator)

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited Certification body.

Test report no.: 028-713173664-000

Date, 2020-05-11

(Abdul Sabbagh)



America

CERTIFICATE

No. U8 020822 0001 Rev. 00

Model(s): ARI-PREMIO, ARI-PREMIO-Plus 2G

Brand Name: ARI-Armaturen

Tested according to: UL 61010-1:2012/R:2016-04
CAN/CSA-C22.2 No. 61010-1:2012/U2:2016-04

Production Facility(ies): 020822

Parameters:

ARI-PREMIO:

Type:	2.2 kN	5.0 kN	12.0 kN	15.0 kN	25.0 kN
Voltage:	100-240 V	100-240 V	100-240 V	100-240 V	100-240 V
Power:	22 VA	22 VA	65 VA	65 VA	130 VA
Frequency:	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Protection class:	I	I	I	I	I

Type:	2.2 kN	5.0 kN	12.0 kN	15.0 kN	25.0 kN
Voltage:	24 VAC/DC	24 VAC/DC	24 VAC/DC	24 VAC/DC	24 VAC/DC
Power:	22 VA	22 VA	65 VA	65 VA	130 VA
Frequency:	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Protection class:	I	I	I	I	I

ARI-PREMIO-Plus 2G:

Type:	2.2 kN	5.0 kN	12.0 kN	15.0 kN	25.0 kN
Voltage:	100-240 V	100-240 V	100-240 V	100-240 V	100-240 V
Power:	31.2 VA	31.2 VA	60 VA	60 VA	130 VA
Frequency:	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Protection class:	I	I	I	I	I

Type:	2.2 kN	5.0 kN	12.0 kN	15.0 kN	25.0 kN
Voltage:	24 VAC/DC	24 VAC/DC	24 VAC/DC	24 VAC/DC	24 VAC/DC
Power:	31.2 VA	31.2 VA	60 VA	60 VA	130 VA
Frequency:	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Protection class:	I	I	I	I	I