



ITIS BV
Columbusweg 64
NL-4462 HB Goes
T +31 113568515
info@itis-nl.com
www.itis-nl.com

Test certificate:
202000275-C001 Rev.1



Industrie Service

API 607 FIRE TEST QUALIFICATION CERTIFICATE

This certificate is to certify that the valve below has been tested in accordance with, and meets all requirements stated in API Standard 607, seventh edition, June 2016 'Fire Test for Quarter-turn Valves and Valves Equipped with Nonmetallic Seats'.

Test valve details

Manufacturer : Comeval Valve Systems S.L. y CIA
Address : Les Rotes 15, E-46540 EL PUIG (Valencia, ES)
Brand : UNIFLOW
Nominal size : 4 inch
Pressure rating : Class 300
Flow direction : Bi-directional
Type : Floating Ball valve
Weight : 96kg
Bore : Full bore
Drawing number : GDBF_A3_100 date:13-07-2020 Rev. 0
Body material : A105
Body gasket material : 2x 304 + Graphite sealing ring
Ball material : A105 + NI60
Seat material : PTFE
Stem material : 17-4PH
Stem seal material : Graphite
Identification number : 20-06262-31
Gearbox : N.a.

Scope of other sizes and pressures ratings qualified by this test according to API 607

Tested valve	Scope of Size	Scope of pressure rating
NPS 4 Class 300	NPS 4; 5; 6; 8 API 6D DN 100; 125; 150; 200	Class 300; 400; 600

This certificate refers to the above mentioned test valve. This certificate does not imply assessment of the production of the valves. This certificate is only valid in conjunction with the full ITIS BV test report number 202000275-R001 Rev.1

Approved signatory

☒ TESTED
☐ REVIEW
☐ WITNESSED
Date/Signature

J. van der Hoeft

14-09-2020

Industrial Testing &
Inspection Services

ITIS

Name Authority (TUV SUD)



Mr. I. van Remoortere

14-09-2020