



ITIS BV
Columbusweg 64
NL-4462 HB Goes
T +31 113568515
info@itis-nl.com
www.itis-nl.com

Test certificate:
202100462-C001



Industrie Service

API 607 FIRE TEST QUALIFICATION CERTIFICATE

This certificate is to certify that the valve below has been tested in accordance with, and meets the requirements for operability, through seat leakage and external leakage stated in API Standard 607, seventh edition, June 2016 'Fire Test for Quarter-turn Valves and Valves Equipped with Nonmetallic Seats'.

Test valve details

Manufacturer : Comeval Valve Systems S.L. y CIA
Address : Les Rotes 15, E-46540 El Puig, Valencia (ES)
Brand : UNIFLOW
Nominal size : DN50
Pressure rating : Class 150
Flow direction : Bi-directional
Type : Floating Ball valve
Weight : 12.0kg
Bore : Full bore
Drawing number : flanged_stainless_carbon_steel_floating_ball_valves_fire_proof-bv4m-uniflow-general_drawing-en, Rev.211115 date: 15-11-2021
Body material : WCB
Body gasket : 2x Graphite
Ball material : CF8
Seat material : PTFE
Stem material : SUS304
Stem seal material : 3x Graphite
Identification number : 20-07669-01
Gearbox : n.a.

According to API standard 607, the specified range for covering other sizes/pressure classes is:

Tested valve	Scope of Size	Scope of pressure rating
NPS 2 Class 150	NPS 2 ¹ / ₁₆ and below; 2 ⁹ / ₁₆ ; 3 ¹ / ₁₆ ; 3 ¹ / ₈ ; 4 ¹ / ₁₆ API 6D NPS 2 and below; 2 ¹ / ₂ ; 3; 4 API 6A DN 50 and below; 65; 80; 100	Class 150; 300

Disclaimer: Under no circumstances ITIS B.V. can be held responsible applying the above mentioned covering range

This certificate refers to the above mentioned test valve. This certificate does not imply assessment of the production of the valves. This certificate is only valid in conjunction with the full ITIS BV test report number 202100462-R001.

Approved signatory	Name Authority (TÜV SÜD)
 J. VAN DER HOFF  J. van der Hoeff 07-02-2022	 Mr. I. van Remoortere 07-02-2022