



ITIS BV
Columbusweg 64
NL-4462 HB Goes
T +31 113568515
info@itis-nl.com
www.itis-nl.com

Test certificate:
202300125-C002



API 6FA FIRE TEST QUALIFICATION CERTIFICATE

This certificate is to certify that the valve below has been tested in accordance with, and meets the requirements for operability, through seat leakage and external leakage stated in API Standard 6FA, fifth edition May 2020 'Standard for Fire Test for Valves'.

Test valve details

Manufacturer : COMEVAL VALVE SYSTEMS S.L. y CIA
Address : Les Rotes 15, 46540 El Puig, Valencia (ES)
Brand : UNIFLOW
Nominal size : DN150 (6")
Pressure rating : Class 150 (PN20)
Flow direction : Bi-directional
Valve type : Gate valve
Weight : 70Kg
Bore : Full bore
Drawing number + revision : Gate_valve_dn150_class150-uniflow-90-general_drawing-en rev230309
Body material : A216 WCB
Body/bonnet gasket : SS304+Graphite
Stem seal material : Graphite
Identification number : 17-00007-02
Gearbox : N/A

According to API standard 6FA, the specified range for covering other sizes/pressure classes is:

Tested valve	Scope of Size	Scope of pressure rating
NPS 6" / DN150 Class 150	NPS 6, 8, 10, 12 API 6D NPS 7 ¹ / ₁₆ , 9, 11 API 6A DN 150, 200, 250, 300	Class 150, 300

Disclaimer: Under no circumstances ITIS B.V. can be held responsible applying the above mentioned covering range

This certificate is issued under the provision that the Raad voor Accreditatie does not assume any liability and refers to the above mentioned test valve. This certificate does not imply assessment of the production of the valves and is only valid in conjunction with the full ITIS BV test report number 202300125-R002.

Approved signatory		
 J. VAN DER HOFF  J. van der Hoeff 10-05-2023		